

**Combined Inspection and Test Records**

Company: North Wales Model Engineering Society

Department: Site Hut

Date: 28/08/2021

Sheet No 1

About the Appliance						Visual Inspect			PAT Tester Results					Completion Records/Notes		
Appliance Unique ID	Item Description	Voltage	Current/Watts	Class (I, II, III)	***F/T/I	Plug	Cable	Case	Earth Ω (0.1+R) (RPE)	Insulation MΩ (RISO)	Leakage mA (Ileak)	Load Amps/KVA	Polarity (Leads Only)	Comments	OK to USE?	Signature
1	1 Fan Heater Glen 3000	240	> 700	II	13	✓	✓	✓		>19.99	0,10				✓	FS
2	2 Sharp Microwave	240	> 700	I	13	✓ or X	✓	✓	P F	0.09	9.72	0.38			✓	FS
3	3 Morphy Richards Toaster	240	> 700	I	13	✓ or X	✓	✓	0.14	>19.99	0,10				✓	FS
4	4 De Longhi Cooker	240	> 700	I	13	✓ or X	✓	✓	0,39	1.33	0.25				✓	FS
5	5 Black & Decker Jig Saw	240	> 700	II		✓ or X	✓	✓	P F	>19.99	0.10			No Fuse. Tested with spare 13A	✓	FS
6	6 Homefront Water Boiler	240	> 700	I	13	✓ or X	✓	✓	0.17	>19.99	0.10				✓	FS
7	7 Kettle	240	> 700	I	13	✓ or X	✓	✓	0.13	>19.99	0.10				✓	FS
8	8 Drill	240	> 700	I	13	✓ or X	✓	✓	0.35	>19.99	0.10				✓	FS
9	9 Reel Extension Cable	240	> 700	I	13	✓ or X	✓	✓	0.43	>19.99	GOOD				✓	FS
10	10 EGO Battery Charger	240	> 700	II	13	✓ or X	✓	✓	P F	>19.99	0.10				✓	FS
11	11 Power Sander	240	> 700	I	13	✓ or X	✓	✓	0.29	>19.99	0.10				✓	FS
12	12 4 port extension cable	240	> 700	II	13	✓ or X	✓	✓		>19.99	Good				✓	FS
13	14 Single port extension cable	240	> 700	II	13	✓ or X	✓	✓		>19.99	0.10				✓	FS
14						✓ or X			P F	P F	P F	P F	P F			
15						✓ or X			P F	P F	P F	P F	P F			

\*\*\*F/T/I F=Fuse with size under, T=Transformer, I=IEC lead connection